


- Notes (1) The model name label is attached to the control box lid.
 (2) This unit is designed for 2x2 grid ceiling.
 If it is installed on a ceiling other than 2x2 grid ceiling, provide an inspection opening on the control box side.
 (3) Draft prevention function (R) is provided on the panel TC-PSAE-SMW-E only.

Symbol	Content
A	See page 25-26 #1.5/2.0 (7 lines) #0.75/1.0 (5 lines)
B	Exhaust ports #6.35 (1/4") (Steel)
C	Exhaust ports #12.7 (1/2") (Steel)
D1	Power supply connection
D2	Remote control cable and signal wiring connection
F	Suspension bolts #M3 or #M4
G	Outside air opening for ducting (Block out)
H	Air supply opening for ducting #125 (Block out)
J	Inspection opening #100x100



Make a space of 100 or more between the units when installing more than one.

Inspection opening (Refer to note (2))

